



19 August 2021

Pablo Garcia
Senior Manager Sales Support
CenturyLink Chile S.A.
Santa Marta de Huechuraba 6951
Region Metropolitana de Santiago
Santiago de Chile 8600360
Chile

Re: Tier III Certification of Design Documents for the CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 2 & Edificio 3, Phase 1 in Santiago de Chile, Chile

Dear Pablo Garcia,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the mutually dependent sites of CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 2 & Edificio 3, Phase 1 as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 9 February 2021 and 23 July 2021.

This Certification is the combination of the mutually dependent sites of CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 2 and CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 3, Phase 1 and supersedes the Tier III Certification of Design Documents for CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 2 with 22 February 2019 expiry.

This Certification recognizes the CenturyLink Chile S.A. – Santiago Datacenter DC-1 Edificio 2 & Edificio 3, Phase 1 design as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 751 kilowatts (kW). Edificio 2 includes 243 kW of alternating current (AC) in the data hall. Edificio 3, Phase 1 includes 300 kW of AC IT load in Data Center Room 1; 200 kW of AC IT load in Data Center Room 2; and 8 kW of direct current (DC) IT load in the Carter Room (Carrier).

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier Certification of Design Documents award is valid until 19 August 2023, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,

Christopher Brown
Chief Technical Officer