

Alberto Alves
Director Data Center Design & Construction
Cirion Technologies
SA01: Avenida Eid Mansur, 666 - Parque São George
Cotia, São Paulo 06708-070
Brazil



9 January 2026

Tier III Certification of Constructed Facility for Cirion Technologies do Brasil LTDA – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8 in Rio de Janeiro, Brazil

Dear Alberto Alves,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Constructed Facility for the Cirion Technologies do Brasil LTDA – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8 as fulfilling Tier III Concurrently Maintainable criteria. The Tier Certification is based on the design, facility demonstrations, the on-site verification of the constructed facility completed between 22 January and 18 August 2025, and the documentation subsequently submitted through 8 December 2025.

This Certification recognizes that Cirion Technologies do Brasil LTDA – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8 is capable of supporting any planned work on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier III Certification is limited by the as-demonstrated total peak IT load of 1,151 kilowatts (kW). This includes a 46-kW IT load in DC-5; a 235-kW IT load in DC-6; a 700-kW IT load in DC-7; and a 170-kW IT load in DC-8.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operations-related errors (such as procedural errors during reconfiguration of redundant systems, components, or site infrastructure equipment) may still impact the critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

This Tier III Certification of Constructed Facility represents Cirion Technologies do Brasil's continued investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,



Christopher Brown
Chief Technical Officer