

UptimeInstitute®

13 February 2020

Rodrigo de Oliveira
Director Sales Engineering
CenturyLink Comunicações do Brasil Ltda.
Alameda Vicente Pinzón, 51 – 4º andar
São Paulo, São Paulo – 04547-130
Brazil

Re: Tier III Certification of Design Documents for the CenturyLink Comunicações do Brasil Ltda. – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8, Phases 1-3 in São Paulo, Brazil

Dear Rodrigo de Oliveira,

Uptime Institute Professional Services is pleased to revise the Tier Certification of Design Documents for the CenturyLink Comunicações do Brasil Ltda. – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8, Phases 1-3 as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 3 September 2019 and 30 January 2020.

This Certification supersedes the Tier III Certification of Design Documents for the CenturyLink Comunicações do Brasil Ltda. – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8, Phases 1-3 with 15 February 2023 expiry.

This Certification recognizes the CenturyLink Comunicações do Brasil Ltda. – Rio de Janeiro Datacenters DC-5, DC-6, DC-7, and DC-8, Phases 1-3 design, as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 1,520 kilowatts (kW). DC-5 is certified to support a critical IT load of up to 218 kW. DC-6 is certified to support a critical IT load of up to 434 kW. DC-7 is certified to support a critical IT load of up to 434 kW. DC-8 is certified to support a critical IT load of up to 434 kW. Phase 1 includes DC-5 and DC-6. Phase 2 includes DC-7. Phase 3 includes DC-8.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 15 February 2025, subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
Chief Technical Officer