UptîmeInstitute[®]

19 January 2024

Rodrigo de Oliveira Director Sales Engineering Cirion Technologies do Brasil LTDA Alameda Vicente Pinzon, 51 – 4° andar São Paulo, SP 04547-130 Brazil

Re: Tier III Certification of Design Documents for the Cirion Technologies do Brasil LTDA – Cotia DC-6 to DC-13 and TH03A in Cotia, Brazil

Dear Rodrigo de Oliveira,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the mutually dependent data centers of Cirion Technologies do Brasil LTDA – Cotia DC-6 to DC-13 and TH03A as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 10 August and 15 December 2023.

This Certification is the combination of the mutually dependent data centers of the CenturyLink Communicações do Brasil Ltda – São Paulo Datacenters DC-6, DC-7, DC-8, DC-9, DC-10, DC-11, and DC-12 and the Cirion Technologies Do Brasil LTDA – Cotia DC-13 and TH03A, and <u>supersedes</u> the Tier III Certification of Design Documents for CenturyLink Communicações do Brasil Ltda – São Paulo Datacenters DC-6, DC-7, DC-8, DC-9, DC-10, DC-11, and DC-12 with 30 August 2023 expiry.

This Certification recognizes the Cirion Technologies do Brasil LTDA – Cotia DC-6 to DC-13 and TH03A design as supporting any planned work on the site infrastructure without disrupting operations, as limited by the stated IT capacity of 2,715 kilowatts (kW). This includes 245 kW of alternating current (AC) load in DC-6; 96 kW of AC load in DC-7; 96 kW of AC load in the DC-8; 209 kW of AC load in DC-9; 143 kW of AC load in DC-10; 256 kW of AC load in DC-11; 270 kW of AC load in DC-12; 1,200 kW of AC load in DATA HALL 13; and 200 kW of direct current (DC) load in TELEHOUSE.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 19 January 2026 subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,

Christopher Brown
Chief Technical Officer

hristplin Br