

30 September 2019

Andrés Suspes Lozano
Senior Manager, Infrastructure Engineering Infrastructure Planning & Implementation
CenturyLink Colombia S.A.
Avenida Calle 127 No. 87-51
Bogotá, Bogotá D.C; 111121
Colombia,

Re: Tier III Certification of Constructed Facility for the CenturyLink Colombia S.A. – Colombia XV Datacenter DC-3 in Bogotá, Bogotá D.C., Colombia

Dear Mr. Andrés Suspes Lozano,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Constructed Facility for the CenturyLink Colombia S.A. – Colombia XV Datacenter DC-3 as fulfilling Tier III Concurrently Maintainable criteria. The Tier Certification is based on the design and on-site verification of the constructed facility completed 16 September 2019.

This Certification recognizes the CenturyLink Colombia S.A. – Colombia XV Datacenter DC-3 as supporting any planned work on the site infrastructure without disrupting computer room power and cooling capacity. This Tier III Certification is based on a total IT load of 440.5 kilowatts (kW). This includes Area Blanca room with up to 405-kW total alternating current (AC) IT load, up to 52 kW in Carriers Room with 52-kW total IT load, divided into 34.5 kW of AC IT load and 17.5 kW of direct current (DC) supported by the DC power plant and Nodo Room with up to 18-kW total DC IT load. However, the Certification is limited to a total critical IT load of 440.5 kW based on the as-demonstrated load conditions of the site.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operations-related errors (such as procedural errors during reconfiguration of redundant systems, components, or site infrastructure equipment) may still impact the critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

This Tier III Certification of Constructed Facility represents the culmination of CenturyLink Colombia S.A.'s investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,



Christopher Brown
Chief Technical Officer



20 November 2020

Andrés Suspes Lozano
Sr. Mgr. Infrastructure Engineering
Infrastructure Planning & Implementation
CenturyLink Colombia S.A.S
Avenida Calle 127 No. 87-51
Bogotá, 111121
Colombia

Re: Tier III Certification of Constructed Facility for the CenturyLink Colombia S.A.S – Bogotá Colombia XV Data Center DC-4 in Bogotá, Colombia

Dear Andrés Suspes Lozano,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Constructed Facility for the CenturyLink Colombia S.A.S – Bogotá Colombia XV Data Center DC-4 as fulfilling Tier III Concurrently Maintainable criteria. The Tier Certification is based on the design, facility demonstrations completed September through 1 October 2020, and the on-site verification of the constructed facility completed 5 November 2020.

This Certification recognizes the CenturyLink Colombia S.A.S – Bogotá Colombia XV Data Center DC-4 as supporting any planned work on the site infrastructure without disrupting computer room power and cooling capacity. This Tier III Certification is based on a total IT load of 600 kilowatts (kW). This includes 564 kW of critical IT load in the DC-4 data hall and 36 kW of critical IT load in the Carrier/CPE Room. Rooms noted as Meet-Me Rooms MMR1 and MMR2 are not currently used in the design to support any actively powered IT hardware.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operations-related errors (such as procedural errors during reconfiguration of redundant systems, components, or site infrastructure equipment) may still impact the critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

This Tier III Certification of Constructed Facility represents the CenturyLink Colombia S.A.S' continued investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,

Christopher Brown
Chief Technical Officer